

ENEL Produzione S.p.A. - Centrale Termoelettrica a Biomassa Mercure

Tabella mensile

Analisi Valori Medi

Mensile lineare del 06/2017

DATA	HCl rif. O2 6% convalidato [mg/Nm ³]	CO rif. O2 6% convalidato [mg/Nm ³]	NO2 eq. rif. O2 6% convalidato [mg/Nm ³]	SO2 rif. O2 6% convalidato [mg/Nm ³]	COT rif. O2 6% convalidato [mg/Nm ³]	Polveri rif. O2 6% convalidato [mg/Nm ³]
01/06/2017	0.1	62.3	124.0	1.6	0.0	0.9
02/06/2017	0.1	78.5	123.1	2.2	0.1	0.9
03/06/2017	0.1	51.8	130.9	2.1	0.0	0.9
04/06/2017	0.1	71.4	125.8	2.1	0.0	0.9
05/06/2017	0.1	74.1	117.6	1.1	0.0	0.9
06/06/2017	0.1	81.1	116.4	0.0	0.1	0.9
07/06/2017	0.1	65.2	119.8	0.0	0.1	0.9
08/06/2017	0.1	68.6	118.6	0.1	0.0	0.9
09/06/2017	0.1	46.7	127.1	0.0	0.0	0.9
10/06/2017	0.1	50.5	130.8	0.0	0.0	0.9
11/06/2017	0.1	48.7	130.1	0.0	0.0	0.9
12/06/2017	0.1	59.9	128.0	0.0	0.0	0.9
13/06/2017	0.1	87.0	127.3	0.2	0.1	0.9
14/06/2017	0.1	70.5	133.9	0.6	0.0	0.9
15/06/2017	0.1	45.6	132.8	0.8	0.0	0.9
16/06/2017	0.1	50.6	129.8	1.0	0.0	0.9
17/06/2017	0.1	57.8	129.1	0.9	0.0	0.9
18/06/2017	0.1	62.1	129.5	0.1	0.0	0.9
19/06/2017	0.1	56.5	133.0	0.0	0.2	0.9
20/06/2017	0.1	55.9	130.7	0.1	0.2	0.9
21/06/2017	0.1	81.2	126.0	0.6	0.4	0.9
22/06/2017	0.1	54.7	132.9	0.8	0.1	0.9
23/06/2017	0.1	56.3	124.0	0.4	0.2	0.9
24/06/2017	0.1	61.3	121.0	0.0	0.1	0.8
25/06/2017	0.1	60.3	121.3	0.0	0.1	0.8
26/06/2017	0.1	70.5	120.8	0.9	0.1	0.9
27/06/2017	0.1	44.0	125.9	0.6	0.1	0.9
28/06/2017	0.1	47.0	115.1	0.5	0.2	0.9
29/06/2017	0.1	33.1	116.1	0.6	0.0	0.8
30/06/2017	0.1	42.4	110.1	0.0	0.0	0.8

Soglia	80	200	180	100	240	16
Nr. Superamenti	0	0	0	0	0	0
Max	0.1	87.0	133.9	2.2	0.4	0.9
Min	0.1	33.1	110.1	0.0	0.0	0.8

Tar In Taratura

(3h) Più di 3 ore invalide