

ENEL Produzione S.p.A. - Centrale Termoelettrica a Biomassa Mercure
 Tabella mensile
 Analisi Valori Medi
 Mensile lineare del 09/2018

DATA	HCl rif. O2 6% convalidato [mg/Nm ³]	CO rif. O2 6% convalidato [mg/Nm ³]	NO2 eq. rif. O2 6% convalidato [mg/Nm ³]	SO2 rif. O2 6% convalidato [mg/Nm ³]	COT rif. O2 6% convalidato [mg/Nm ³]	Polveri rif. O2 6% convalidato [mg/Nm ³]
01/09/2018	0.1	37.7	138.5	0.0	0.0	1.2
02/09/2018	0.1	40.8	145.1	0.0	0.0	1.2
03/09/2018	0.1	37.7	143.3	0.0	0.0	1.2
04/09/2018	0.1	43.7	138.7	0.0	0.0	1.3
05/09/2018	0.1	60.8	119.4	0.0	0.0	1.2
06/09/2018	0.1	54.7	129.5	0.0	0.0	1.2
07/09/2018	0.1	44.9	142.2	0.0	0.0	1.3
08/09/2018	0.1	56.1	140.1	0.0	0.0	1.3
09/09/2018	0.1	65.7	131.6	0.0	0.0	1.3
10/09/2018	0.1	43.4	132.7	0.0	0.0	1.3
11/09/2018	0.1	54.9	127.8	0.0	0.0	1.3
12/09/2018	0.1	54.1	146.4	0.0	0.0	1.4
13/09/2018	0.1	73.8	142.3	0.0	0.0	1.3
14/09/2018	0.1	77.1	141.0	0.1	0.2	1.3
15/09/2018	0.1	58.8	142.1	0.0	0.0	1.3
16/09/2018	0.1	63.0	142.4	0.0	0.0	1.3
17/09/2018	0.1	82.6	142.4	0.0	0.2	1.3
18/09/2018	0.1	67.6	135.6	0.0	0.1	1.3
19/09/2018	0.1	57.7	134.2	0.0	0.1	1.4
20/09/2018	0.1	70.5	128.6	0.1	0.5	1.4
21/09/2018	0.1	68.9	137.7	0.3	0.2	1.4
22/09/2018	0.1	63.6	140.4	0.2	0.1	1.3
23/09/2018	0.1	63.4	133.7	0.1	0.2	1.3
24/09/2018	0.1	61.3	133.6	0.2	0.1	1.3
25/09/2018	0.1	23.7	138.5	0.0	0.0	1.4
26/09/2018	0.1	63.4	127.4	7.1	7.3	1.8
27/09/2018						
28/09/2018	0.1	45.3	143.1	0.4	0.0	2.0
29/09/2018	0.2	34.6	139.5	0.0	0.2	1.9
30/09/2018	0.2	35.6	142.6	0.0	0.0	1.8

Soglia	80	200	180	100	240	16
Nr. Superamenti	0	0	0	0	0	0
Max	0.2	82.6	146.4	7.1	7.3	2.0
Min	0.1	23.7	119.4	0.0	0.0	1.2

Tar In Taratura

(3h) Più di 3 ore invalide